

Walkthrough Inspection Checklist

Name: Village IAQ Team
 School: Village School
 Room or Area: ALL Date Completed: 10/17/25
 Signature: [Signature]

Instructions

1. Read the *IAQ Backgrounder* and the Background Information for this checklist.
2. Keep the Background Information and make a copy of the checklist for future reference.
3. Complete the Checklist.
 - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
 - Make comments in the "Notes" section as necessary.
4. Return the checklist portion of this document to the IAQ Coordinator.

1. GROUND LEVEL

	Yes	No	N/A
1a. Ensured that ventilation units operate properly.....	☒	☐	☐
1b. Ensured there are no obstructions blocking air intakes.....	☒	☐	☐
1c. Checked for nests and droppings near outdoor air intakes	☒	☐	☐
1d. Determined that dumpsters are located away from doors, windows, and outdoor air intakes	☒	☐	☐
1e. Checked potential sources of air contaminants near the building (chimneys, stacks, industrial plants, exhaust from nearby buildings)	☒	☐	☐
1f. Ensured that vehicles avoid idling near outdoor air intakes	☒	☐	☐
1g. Minimized pesticide application	☒	☐	☐
1h. Ensured that there is proper drainage away from the building (including roof downspouts)	☒	☐	☐
1i. Ensured that sprinklers spray away from the building and outdoor air intakes	☒	☐	☐
1j. Ensured that walk-off mats are used at exterior entrances and that they are cleaned regularly	☒	☐	☐

2. ROOF

While on the roof, consider inspecting the HVAC units (use the Ventilation Checklist).

2a. Ensured that the roof is in good condition	☒	☐	☐
2b. Checked for evidence of water ponding	☒	☐	☐
2c. Checked that ventilation units operate properly (air flows in)	☒	☐	☐
2d. Ensured that exhaust fans operate properly (air flows out)	☒	☐	☐
2e. Ensured that air intakes remain open, even at minimum setting	☒	☐	☐
2f. Checked for nests and droppings near outdoor air intakes	☒	☐	☐
2g. Ensured that air from plumbing stacks and exhaust outlets flows away from outdoor air intakes	☒	☐	☐

3. ATTIC


3a. Checked for evidence of roof and plumbing leaks	☐	☐	☒
3b. Checked for birds and animal nests	☐	☐	☒

4. GENERAL CONSIDERATIONS

4a. Ensured that temperature and humidity are maintained within acceptable ranges	☒	☐	☐
4b. Ensured that no obstructions exist in supply and exhaust vents	☒	☐	☐
4c. Checked for odors	☒	☐	☐
4d. Checked for signs of mold and mildew growth	☒	☐	☐

4. GENERAL CONSIDERATIONS (continued)

- | | Yes | No | N/A |
|--|-------------------------------------|--------------------------|--------------------------|
| 4e. Checked for signs of water damage | ☒ | ☐ | ☐ |
| 4f. Checked for evidence of pests and obvious food sources | ☒ | ☐ | ☐ |
| 4g. Noted and reviewed all concerns from school occupants | ☒ | ☐ | ☐ |



5. BATHROOMS AND GENERAL PLUMBING

- | | | | |
|--|-------------------------------------|--------------------------|--------------------------|
| 5a. Ensured that bathrooms and restrooms have operating exhaust fans | ☒ | ☐ | ☐ |
| 5b. Ensured proper drain trap maintenance: | | | |
| Water is poured down floor drains once per week (approx. 1 quart of water) | ☒ | ☐ | ☐ |
| Water is poured into sinks at least once per week (about 2 cups of water) | ☒ | ☐ | ☐ |
| Toilets are flushed at least once per week | ☒ | ☐ | ☐ |

6. MAINTENANCE SUPPLIES

- | | | | |
|--|-------------------------------------|--------------------------|--------------------------|
| 6a. Ensured that chemicals are used only with adequate ventilation and when building is unoccupied | ☒ | ☐ | ☐ |
| 6b. Ensured that vents in chemical and trash storage areas are operating properly | ☒ | ☐ | ☐ |
| 6c. Ensured that portable fuel containers are properly closed | ☒ | ☐ | ☐ |
| 6d. Ensured that power equipment, like snowblowers and lawn mowers, have been serviced and maintained according to manufacturers' guidelines | ☒ | ☐ | ☐ |

7. COMBUSTION APPLIANCES

- | | | | |
|--|-------------------------------------|--------------------------|--------------------------|
| 7a. Checked for combustion gas and fuel odors | ☒ | ☐ | ☐ |
| 7b. Ensured that combustion appliances have flues or exhaust hoods | ☒ | ☐ | ☐ |
| 7c. Checked for leaks, disconnections, and deterioration | ☒ | ☐ | ☐ |
| 7d. Ensured there is no soot on inside or outside of flue components | ☒ | ☐ | ☐ |

8. OTHER

- | | | | |
|--|-------------------------------------|--------------------------|--------------------------|
| 8a. Checked for peeling and flaking paint (if the building was built before 1980, this could be a lead hazard) | ☒ | ☐ | ☐ |
| 8b. Determined date of last radon test | ☒ | ☐ | ☐ |

NOTES

See Attache 2

10.2025 Inspection Notes:

- AC vent @ entrance of building: black and dirty tiles surrounding
- Gym HVAC vents missing distribution caps
- Cafe vents visible mold/mildew
- Mold/mildew vents bathrooms 2/4, 6/8
- Mold/mildew over room 7 entryway
- Black ceiling tiles room 5
- Room 3 radiator leakage into classroom
- Mold/mildew room T4 tiles
- Mold/mildew Mezzanine vents
- Room 21 ceiling tiles mold/mildew near sprinklers
- Room 20 ceiling tiles mold/mildew
- Room 18 ceiling tiles mold/mildew near sprinklers
- Corner side by prek playground missing gutter
- AC duct by prek in hallway dirty
- Significant dust on room 13 sprinkler head
- Gutters growing weeds above room 14/16
- No ventilation within PE office
- T4 missing tiles
- T4 heating/cooling leaking into classroom
- Social work office heating leaking into office
- Maintenance supplies kept in auxiliary building
- Lock broken on therapy pool supply cabinet