

Walkthrough Inspection Checklist

Name: IAQ Woodbury Team

School: ACES International Preschool, Woodbury

Room or Area: ALL Date Completed: 10/7/26

Signature:

Instructions

1. Read the *IAQ Backgrounder* and the Background Information for this checklist.
2. Keep the Background Information and make a copy of the checklist for future reference.
3. Complete the Checklist.
   - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
   - Make comments in the "Notes" section as necessary.
4. Return the checklist portion of this document to the IAQ Coordinator.

1. GROUND LEVEL

		Yes	No	N/A
1a.	Ensured that ventilation units operate properly	☑	☐	☐
1b.	Ensured there are no obstructions blocking air intakes	☑	☐	☐
1c.	Checked for nests and droppings near outdoor air intakes	☑	☐	☐
1d.	Determined that dumpsters are located away from doors, windows, and outdoor air intakes	☑	☐	☐
1e.	Checked potential sources of air contaminants near the building (chimneys, stacks, industrial plants, exhaust from nearby buildings)	☑	☐	☐
1f.	Ensured that vehicles avoid idling near outdoor air intakes	☑	☐	☐
1g.	Minimized pesticide application	☐	☐	☑
1h.	Ensured that there is proper drainage away from the building (including roof downspouts)	☑	☐	☐
1i.	Ensured that sprinklers spray away from the building and outdoor air intakes	☑	☐	☐
1j.	Ensured that walk-off mats are used at exterior entrances and that they are cleaned regularly	☑	☐	☐

2. ROOF

While on the roof, consider inspecting the HVAC units (use the Ventilation Checklist*).*

2a.	Ensured that the roof is in good condition	☐	☑	☐
2b.	Checked for evidence of water ponding	☑	☐	☐
2c.	Checked that ventilation units operate properly (air flows in)	☑	☐	☐
2d.	Ensured that exhaust fans operate properly (air flows out)	☑	☐	☐
2e.	Ensured that air intakes remain open, even at minimum setting	☑	☐	☐
2f.	Checked for nests and droppings near outdoor air intakes	☑	☐	☐
2g.	Ensured that air from plumbing stacks and exhaust outlets flows away from outdoor air intakes	☑	☐	☐

3. ATTIC

3a.	Checked for evidence of roof and plumbing leaks	☑	☐	☐
3b.	Checked for birds and animal nests	☑	☐	☐

4. GENERAL CONSIDERATIONS

4a.	Ensured that temperature and humidity are maintained within acceptable ranges	☑	☐	☐
4b.	Ensured that no obstructions exist in supply and exhaust vents	☑	☐	☐
4c.	Checked for odors	☑	☐	☐
4d.	Checked for signs of mold and mildew growth	☑	☐	☐

4. GENERAL CONSIDERATIONS (continued)



	Yes	No	N/A
4e. Checked for signs of water damage	☑	☐	☐
4f. Checked for evidence of pests and obvious food sources	☑	☐	☐
4g. Noted and reviewed all concerns from school occupants	☑	☐	☐

5. BATHROOMS AND GENERAL PLUMBING

5a. Ensured that bathrooms and restrooms have operating exhaust fans	☐	☑	☐
5b. Ensured proper drain trap maintenance:			
Water is poured down floor drains once per week (approx. 1 quart of water)	☑	☐	☐
Water is poured into sinks at least once per week (about 2 cups of water)	☑	☐	☐
Toilets are flushed at least once per week	☑	☐	☐

6. MAINTENANCE SUPPLIES

6a. Ensured that chemicals are used only with adequate ventilation and when building is unoccupied	☑	☐	☐
6b. Ensured that vents in chemical and trash storage areas are operating properly	☐	☐	☑
6c. Ensured that portable fuel containers are properly closed	☐	☐	☑
6d. Ensured that power equipment, like snowblowers and lawn mowers, have been serviced and maintained according to manufacturers' guidelines	☐	☐	☑

7. COMBUSTION APPLIANCES

7a. Checked for combustion gas and fuel odors	☑	☐	☐
7b. Ensured that combustion appliances have flues or exhaust hoods	☐	☐	☑
7c. Checked for leaks, disconnections, and deterioration	☐	☐	☑
7d. Ensured there is no soot on inside or outside of flue components	☐	☐	☑

8. OTHER

8a. Checked for peeling and flaking paint (if the building was built before 1980, this could be a lead hazard)	☑	☐	☐
8b. Determined date of last radon test	☑	☐	☐

NOTES

Walkthrough Inspection Checklist

ACES International Preschool and Childcare Center, Woodbury

Notes

Drainage

- Gutters need cleaning
- Water runs over gutter drain by front door and possibly by the drain in the back playground

Vents and Exhausts

- Exhaust not working in staff bathroom by main office
- Vent in staff bathroom by gym needs to be cleaned

Lights

Some light covers need to be cleaned

Stairwell by RSG needs new light bulbs

Ceiling Tiles

Water damage in Nursery 2 and Poppies room by Main Office

Doors/Windows

Lock not working in Nursery 2

Egress door sticks and difficult to open in Sweet Peas 2 (Carissa's room)

Window Screens need to be replaced